

II

(Acts whose publication is not obligatory)

COMMISSION

COMMISSION DECISION

of 3 May 2000

implementing Council Directive 89/106/EEC as regards the classification of the resistance to fire performance of construction products, construction works and parts thereof

(notified under document number C(2000) 1001)

(Text with EEA relevance)

(2000/367/EC)

THE COMMISSION OF THE EUROPEAN COMMUNITIES,

Having regard to the Treaty establishing the European Community,

Having regard to Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products ⁽¹⁾, as amended by Directive 93/68/EEC ⁽²⁾, and in particular Articles 3, 6 and 20 thereof,

Whereas:

- (1) Article 3(2) and (3) of Directive 89/106/EEC state that, in order to take account of different levels of protection for the construction works that may prevail at national, regional or local levels, each essential requirement may give rise to the establishment of classes of the interpretative documents. Those documents have been published as the Communication of the Commission with regard to the interpretative documents of Council Directive 89/106/EEC ⁽³⁾.
- (2) Paragraph 4.2.1 of interpretative document No 2 justifies the need for different levels of the essential requirement 'Safety in case of fire' as a function of the type, use and location of the construction work, its layout and the availability of the emergency facilities.
- (3) Paragraph 2.2 of interpretative document No 2 lists a number of interrelated measures for the satisfaction of the essential requirement 'Safety in case of fire' that together contribute to define the fire safety strategy that can be developed in different ways in Member States.
- (4) Paragraph 4.3.1.3 of interpretative document No 2 identifies one of these measures prevailing in Member States that relates to the resistance to fire performance of construction products and/or parts of construction works.
- (5) To enable the resistance to fire performance of construction products and construction works or parts thereof to be evaluated, the harmonised solution consists in a system of classes that is included in interpretative document No 2.

⁽¹⁾ OJ L 40, 11.2.1989, p. 12.

⁽²⁾ OJ L 220, 30.8.1993, p. 1.

⁽³⁾ OJ C 62, 28.2.1994, p. 1.

- (6) This system of classes has been adapted to technical progress in a mandate from the Commission to the European standardisation bodies, CEN and Cenelec.
- (7) Article 6(3) of Directive 89/106/EEC states that the Member States may determine the performance levels to be observed in their territory only within the classifications adopted at Community level and only subject to the use of all or some classes or one class.
- (8) The measures provided for in this Decision are in accordance with the opinion of the Standing Committee on Construction,

HAS ADOPTED THIS DECISION:

Article 1

The classification system adopted at Community level for the resistance to fire performance of construction products, construction works and parts thereof shall be as set out in the Annex.

Article 2

This Decision is addressed to the Member States.

Done at Brussels, 3 May 2000.

For the Commission
Erkki LIIKANEN
Member of the Commission

ANNEX

DEFINITIONS, TESTS AND PERFORMANCE CRITERIA

The relevant definitions, tests and performance criteria are fully described in, or referenced from, the European standards referred to in this Annex.

SYMBOLS

R	Load-bearing capacity
E	Integrity
I	Insulation
W	Radiation
M	Mechanical action
C	Self-closing
S	Smoke leakage
P or PH	Continuity of power and/or signal supply
G	Soot fire resistance
K	Fire protection ability

Notes

- The following classifications are expressed in minutes unless otherwise specified.
- The European standards EN 13501-2, EN 13501-3 (classification) and EN 1992-1.2, EN 1993-1.2, EN 1994-1.2, EN 1995-1.2, EN 1996-1.2, EN 1999-1.2 (Eurocodes) referred to in this Decision shall be subject to the same safeguard procedures as described in Article 5(1) of Directive 89/106/EEC.

CLASSIFICATIONS

1. Load-bearing elements without a fire separating function

Applies to	walls, floors, roofs, beams, columns, balconies, stairs, walkways
Standard(s)	EN 13501-2; EN 1365-1,2,3,4,5,6; EN 1992-1.2; EN 1993-1.2; EN 1994-1.2; EN 1995-1.2; EN 1996-1.2; EN 1999-1.2
Classification:	
R	15 20 30 45 60 90 120 180 240 360
Notes	—

2. Load-bearing elements with a fire-separating function

Applies to	Walls
Standard(s)	EN 13501-2; EN 1365-1; EN 1992-1.2; EN 1993-1.2; EN 1994-1.2; EN 1995-1.2; EN 1996-1.2; EN 1999-1.2
Classification:	
RE	20 30 60 90 120 180 240
REI	15 20 30 45 60 90 120 180 240
REI-M	30 60 90 120 180 240
REW	20 30 60 90 120 180 240
Notes	—

Applies to	floors and roofs									
Standard(s)	EN 13501-2; EN 1365-2; EN 1992-1.2; EN 1993-1.2; EN 1994-1.2; EN 1995-1.2; EN 1999-1.2									
Classification:										
RE		20	30		60	90	120	180	240	
REI	15	20	30	45	60	90	120	180	240	
Notes	—									

3. Products and systems for protecting load-bearing elements or parts of the works

Applies to	ceilings with no independent fire resistance									
Standard(s)	EN 13501-2; EN 13381-1									
Classification: expressed in the same terms as for the load-bearing element being protected										
Notes	If also fulfilling the requirements with regard to the 'semi-natural' fire, the symbol 'sn' is added to the classification.									
Applies to	fire protective coatings, claddings and screens									
Standard(s)	EN 13501-2; EN 13381-2 to 7									
Classification: expressed in the same terms as for the load-bearing element being protected										
Notes	—									

4. Non-loadbearing elements or parts of works and products therefor

Applies to	partitions (including those incorporating uninsulated portions)									
Standard(s)	EN 13501-2; EN 1364-1; EN 1992-1.2; EN 1993-1.2; EN 1994-1.2; EN 1995-1.2; EN 1996-1.2; EN 1999-1.2									
Classification:										
E		20	30		60	90	120			
EI	15	20	30	45	60	90	120	180	240	
EI-M			30		60	90	120			
EW		20	30		60	90	120			
Notes	—									
Applies to	ceilings with independent fire resistance									
Standard(s)	EN 13501-2; EN 1364-2									
Classification:										
EI	15		30	45	60	90	120	180	240	
Notes	The classification is completed by '(a → b)', '(b → a)', or '(a ↔ b)' to indicate whether the element has been tested and fulfils the requirements from above or below only or both.									

Applies to	facades (curtain walls) and external walls (including glazed elements)
Standard(s)	EN 13501-2; EN 1364-3,4,5,6; EN 1992-1.2; EN 1993-1.2; EN 1994-1.2; EN 1995-1.2; EN 1996-1.2; EN 1999-1.2

Classification:

E	15		30		60	90	120			
EI	15		30		60	90	120			
EW		20	30		60					

Notes	The classification is completed by '(i → o)', '(o → i)', or '(i ↔ o)' to indicate whether the element has been tested and fulfils the requirements from the inside or outside only or both. Where required, mechanical stability means that there are no falling parts liable to cause personal injury during the time for the E or EI classification.
-------	---

Applies to	raised floors
Standard(s)	EN 13501-2; EN 1366-6

Classification:

R	15		30							
RE			30							
REI			30							

Notes	The classification is completed by the addition of the suffix 'f' to indicate full fire resistance or 'r' to indicate exposure to the reduced constant temperature exposure only.
-------	---

Applies to	penetration seals and linear gap seals
Standard(s)	EN 13501-2; EN 1366-3,4

Classification:

E	15		30	45	60	90	120	180	240	
EI	15	20	30	45	60	90	120	180	240	
Notes	—									

Applies to	fire doors and shutters (including those that incorporate glazing and hardware) and their closing devices
Standard(s)	EN 13501-2; EN 1634-1

Classification:

E	15	20	30	45	60	90	120	180	240	
EI	15	20	30	45	60	90	120	180	240	
EW		20	30		60					

Notes	The I classification is completed by the addition of the suffix '1' or '2' to indicate which definition of insulation is used. The addition of the symbol 'C' indicates that the product also satisfies the 'self-closing' criterion (pass/fail test) ⁽¹⁾ .
-------	--

⁽¹⁾ The 'C' classification may be complemented by the digits 0 to 5 according to the use category. Details shall be included in the relevant product technical specification.

Applies to	smoke control doors									
Standard(s)	EN 13501-2; EN 1634-3									
Classification: S ₂₀₀ or S _a depending upon the test conditions fulfilled										
Notes	The addition of the symbol 'C' indicates that the product also satisfies the 'self-closing' criterion (pass/fail test) (!).									
(!) The 'C' classification may be complemented by the digits 0 to 5 according to the use category. Details shall be included in the relevant product technical specification.										
Applies to	closures for conveyers and trackbound transportation systems									
Standard(s)	EN 13501-2; EN 1366-7									
Classification:										
E	15		30	45	60	90	120	180	240	
EI	15	20	30	45	60	90	120	180	240	
EW		20	30		60					
Notes	The I classification is completed by the addition of the suffix '1' or '2' to indicate which definition of insulation is used. The addition of the symbol 'C' indicates that the product also satisfies the 'self-closing' criterion (pass/fail test) (!).									
(!) The 'C' classification may be complemented by the digits 0 to 5 according to the use category. Details shall be included in the relevant product technical specification.										
Applies to	service ducts and shafts									
Standard(s)	EN 13501-2; EN 1366-5									
Classification:										
E	15	20	30	45	60	90	120	180	240	
EI	15	20	30	45	60	90	120	180	240	
Notes	The classification is completed by '(i → o)', '(o → i)', or '(i ↔ o)' to indicate whether the element has been tested and fulfils the requirements from the inside or outside only or both. In addition, the symbols 'v _e ' and/or 'h _o ' indicate the suitability for vertical and/or horizontal use.									
Applies to	chimneys									
Standard(s)	EN 13501-2; EN 13216									
Classification: G + distance in mm (e.g. G 50)										
Notes	Distance not required for built-in products.									
Applies to	wall and ceiling coverings									
Standard(s)	EN 13501-2; EN 13381-8									
Classification: K										
Notes	Pass/fail test.									

5. Products for use in ventilation systems (excluding smoke and heat exhaust ventilation)

Applies to	ventilation ducts									
Standard(s)	EN 13501-3; EN 1366-1									
Classification:										
EI	15	20	30	45	60	90	120	180	240	
E			30		60					
Notes	The classification is completed by '(i → o)', '(o → i)', or '(i ↔ o)' to indicate whether the element has been tested and fulfils the requirements from the inside or outside only or both. In addition, the symbols 'v _e ' and/or 'h _o ' indicate the suitability for vertical and/or horizontal use. The addition of the symbol 'S' indicates the satisfaction of an extra restriction on leakage.									
Applies to	fire dampers									
Standard(s)	EN 13501-3; EN 1366-2									
Classification:										
EI	15	20	30	45	60	90	120	180	240	
E			30		60	90	120			
Notes	The classification is completed by '(i → o)', '(o → i)', or '(i ↔ o)' to indicate whether the element has been tested and fulfils the requirements from the inside or outside only or both. In addition, the symbols 'v _e ' and/or 'h _o ' indicate the suitability for vertical and/or horizontal use. The addition of the symbol 'S' indicates the satisfaction of an extra restriction on leakage.									

6. Products to be used within services

Applies to	electrical and fibre-optic cables and accessories; conduits and fire protective systems for cables									
Standard(s)	EN 13501-3									
Classification:										
P	15		30		60	90	120			
Notes	—									
Applies to	small diameter power or signal cables or systems (<20 mm diameter and with conductor sizes ≤2.5 mm ²)									
Standard(s)	EN 13501-3; EN 50200									
Classification:										
PH	15		30		60	90	120			
Notes	—									